


# PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

File No. P.H.C. S.D. &amp; S.C. 03/2025-26

Date: 25-6-2025

It is certified that an inspection team headed by Medical Officer, Primary Health Center, Doddasiddavvanahalli inspected the JNANAPOORNA INTERNATIONAL SCHOOL, at Doddasiddavvanahalli Chitradurga, Chitradurga Taluk and Dt. Karnataka on 24-06-2025 and on the basis of water test report attached bearing no 01/2025-26 dated 16-06-2025 of Rural Drinking Water and Sanitation Division, Chitradurga Certificated that the JNANAPOORNA INTERNATIONAL SCHOOL, has safe drinking water facilities for the students and members of staff of the institution. The school is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T Govt.

The above is valid for a period of One year.



TRANSLATED

To,

**JNANAPOORNA INTERNATIONAL SCHOOL**

D.S. Halli (Doddasiddavvanahalli),

Chitradurga Taluk &amp; District

Signature with Seal

Name: ಸೃಷ್ಟಿ ಕೆ.ಎಸ್.ಎಸ್.

ಮೈಸೂರು ಆರೋಗ್ಯ ಕೇಂದ್ರ  
ಸಿದ್ಧಲಿಂಗಪುರ, ಚಿತ್ರದುರ್ಗ ಜಿಲ್ಲೆ

Name &amp; Address of the Office Department

MEDICAL OFFICER

P.H. Center,

DODDASIDDAYANAHALLI

CHITRADURGA TALUK

ATTESTED BY ME

NOTARY  
Govt of India  
Date 28/6/2025

Vijayashree. S

PRINCIPAL

JNANAPOORNA INTERNATIONAL SCHOOL  
Doddasiddavvanahalli, Chitradurga Taluk & Dist

Note: This certificate is to be issued by the authority JNANAPOORNA INTERNATIONAL SCHOOL  
Sunanda Vidya Samsthe (R)  
B.L.Gowda Layout  
Behind RTO Office, Chitradurga.



# RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK

Chitradurga District Water Quality Testing Laboratory  
ZillaPanchayathPremesis, Stadium Road, Chitradurga - 577501



## Test Report

Name: jnanapurna school

Date : 16-06-2025

Source: BORE WELL

Adress: Dodda siddavana halli

Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
1	pH Value @Temp25°C	7.46	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2	Specific Conductance, $\mu\text{S}/\text{cm}$ @Temp25°C	1525	–	–	IS 3025 (Part-14) : 2013
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5) : 2018
4	Taste	-	Agreeable	Agreeable	IS 3025 (Part-8) : 2023
5	Colour, Hazen Units	01	5	15	IS 3025 (Part-4) : 2021
6	Turbidity, NTU	0.3	1	5	IS 3025 (Part-10) : 2023
7	Total Dissolved Solids@ 180°C, mg/l	740	500	2000	IS 3025 (Part-16) : 2023
8	Alkalinity as $\text{CaCO}_3$ , mg/l	268	200	600	IS 3025 (Part-23) : 2023
9	Total Hardness as $\text{CaCO}_3$ , mg/l	304.2	200	600	IS 3025 (Part-21) : 2009
10	Calcium as Ca, mg/l	70.5	75	200	IS 3025 (Part-40) : 2024
11	Magnesium as Mg, mg/l	31.1	30	100	IS 3025 (Part-46) : 2023
12	Chloride as Cl, mg/l	123.9	250	1000	IS 3025 (Part-32) : 1988
13	Sulphate as $\text{SO}_4$ , mg/l	47	200	400	IS 3025 (Part-24) : 2022
14	Fluoride as F, mg/l	1.37	1	1.5	APHA 24th Edition
15	Nitrate as $\text{NO}_3$ , mg/l	41	45	No relaxation	APHA 24th Edition
16	Iron as Fe, mg/l	0.22	1	No relaxation	IS 3025 (Part-53) : 2024
Remarks : The above tested sample meets the requirement of IS 10500:2012 RA 2018 drinking water specification for the above tested parameters only.					
Analysed by :  Junior Analyst : Vinutha T			Checked by :  Senior Analyst : Swathi Nadig N P		

**NOTE: The above results relate only to the sample tested.**

  
**SECRETARY**  
Sunanda Vidya Samsthe (R)  
B.L.Gowda Layout  
Behind RTO Office, Chitradurga.

  
**PRINCIPAL**  
JNANAPOORNA INTERNATIONAL SCHOOL  
Doddasiddavvanahalli, Chitradurga Tq & Dist